



**BUREAU
VERITAS**

Ref: BVIPL/SPL/BL/630/6/2017/97
Test Order dated: 07.06.2017

Date: 21.07.2017

*NABL Accredited Lab
as per ISO / IEC: 17025*

M/s. United Office Systems Pvt. Ltd.,
Plot No. -62/1, 2 & 3, Vill-Vankas,
Taluka-Umbergoan,
Dist. Valsad - 396150,
Gujarat


TEST REPORT ON ACCESS FLOORING SYSTEM

Source of sample / material	:	Access Flooring System verified at M/s United Office Systems Pvt. Ltd.
Customer reference	:	Email dated: 07.05.2017 and 14.07.2017
Date of test	:	10.06.2017
Tests Conducted	:	Uniform Load Test
Sample Identification*	:	Steel Cementious Panels (Corner Lock /Laminated)
Product Model No.*	:	"UNITILE USF LFW 30 0800
Product code No.*	:	UNITILE USF LFW 30 0800"
Equipment*	:	U.T.M (Load Cell, Sr. No. 400432, Maximum Capacity 4 Ton Calibration date: 30.03.2017, Due date: 30.03.2018 & Digital Dial Indicator, Sr.No. 030948 Calibration date : 09.03.2017, Due date: 08.03.2018)
Panel size (Nominal)*	:	600 mm x 600 mm
Thickness /Gross weight of Panel*	:	30 mm/ 13.200 kg.
Test Method	:	CISCA 2007, Section-7
Witness by/Date of visit	:	Mr. Radhakrishna, Consultant Bureau Veritas, India Pvt.Ltd, Bangalore on 10.6.17

TEST RESULTS

Uniform Load Test:-

Sample reference	UNITILE USF LFW 30 0800
Test height in mm.	300
Location of measurement	Center
Deflection(mm) at pre-load of 50lb/ft ²	0
Load Withstand Maximum Load at 2.54 mm Deflection	1820 kg./m ²
Residual deflection (mm) at pre-load	0.12



UNITILE USF LFW 30 0800 - TEST UNDER PROGRESS

* As furnished by the customer

- Note:**
1. The results relate only to the items tested.
 2. Report shall not be reproduced, except in full without the written approval of the lab.
 3. Any correction invalidates this report.

for BUREAU VERITAS (INDIA) PRIVATE LIMITED
Construction Services Laboratory

Bureau Veritas (India) Private Limited
(Construction Services Laboratory)
43, 45-47, Pete Chennappa As, 1st Floor,
Magadi Road, Kamakshipalya, Bangalore - 560 079
Tel.: +91 80 23011800 Fax: +91 80 26716833
bangalore.lab@in.bureauveritas.com

SANJEEV PATGAR
Manager LAB

Regd. Off. : Marwah Centre, 6th Floor
K. Marwah Marg, Off Saki-Vihar Road
Andheri (East), Mumbai - 400 072. India
Tel.: +91 22 66956300 Fax: +91 22 66956309
www.bureauveritas.co.in
CIN : U74210MH2001PTC134262

Offices/Labs at: Ahmedabad, Baroda
Bhopal, Chennai, Cochin, Coimbatore
Delhi, Goa, Hubli, Hyderabad, Indore
Jaipur, Kakinada, Kandla, Kolkata, Ludhiana
Mangalore, Nagpur, Nashik, Pune, Raipur
Surat, Trichy & Visakhapatnam